



Notified Body No 1023
INSTITUTE FOR TESTING AND CERTIFICATION, Plc
Trida Tomase Bati 299, Louky, 763 02 Zlin, CZECH REPUBLIC

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No 1023-CPR-0557 P

Construction product type: **ASD Laminat Compact FR Line – compact laminate panels for external wall and ceiling finishes, HPL-EGF $t \geq 6$ mm laminate**

Product parameters: *Reaction to fire class: B-s2, d0, intended use: external wall and ceiling finishes*

Placed on the market under the name or trade mark of: **ASD LAMINAT ANONİM ŞİRKETİ**
Yeşilköy mah. Atatürk cad. İstanbul Dünya Ticaret Merkezi
Blokları A1 blok No: 10/1 Kat:16 ofis no: 463-465-466
Bakırköy-İSTANBUL, Turkey

Relevant standard(s): **EN 438-7:2005** High-pressure decorative laminates (HPL) Sheets based on thermosetting resins (Usually called Laminates) – Part 7: Compact laminate and HPL composite panels for internal and external wall and ceiling finishes

Report No: **753500934B/2013, 343505950/2016, 343506570/2017**


Certificate first issued on: **2013-12-16**

Notified Body No 1023, in compliance with Regulation (EU) No 305/2011 (CPR), attests that:

- All provisions relating to the Assessment and Verification of Constancy of Performance (AVCP) described in Annex ZA of the above harmonized standard(s) under **AVCP System 1** have been applied
- The performance of the construction product above has been assessed to ensure the constancy of performance of the construction product.

The assessment of performance of the construction product and findings from the initial inspection of the manufacturing plant and factory production control are summarized in the above mentioned Supervision Report.

This certificate remains valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the Notified Body.




Dr. Radomír ČEVELÍK

Representative of Notified Body No 1023

Revision b): 2017-12-29

Replaces the withdrawn certificate 1023-CPR-0557 P (Revision a) issued on 2016-12-31